

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF DEXTER-ALMO HEIGHTS)	
WATER DISTRICT FOR A DEVIATION PURSUANT)	CASE NO.
TO 807 KAR 5:066, SECTION 5(4), REGARDING)	91-399
WATER STORAGE)	

O R D E R

On October 31, 1991, the Dexter-Almo Heights Water District ("Dexter-Almo") filed an application for a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which requires that each utility shall maintain water storage to ensure a minimum of one day's supply of its average daily water usage. Dexter-Almo filed the application for a deviation in response to a Commission Utility Inspection Report dated August 28, 1991 which stated that Dexter-Almo was in violation of 807 KAR 5:066, Section 5(4).

On December 17, 1991, Dexter-Almo filed a letter from the City of Murray Public Works and Utilities ("City of Murray") which indicated and assured that it would provide Dexter-Almo's needed storage for the next three years from its 3.2 million gallons of storage capacity.

The Commission, having reviewed the application and information submitted subsequent thereto, and being otherwise sufficiently advised, finds that:

1. Dexter-Almo has no water storage tanks in its distribution system.


2. Dexter-Almo's average daily water usage is approximately 80,000 gallons per day.


3. The City of Murray is willing to provide Dexter-Almo with needed storage capacity for the next three years.


IT IS THEREFORE ORDERED that Dexter-Almo be and it hereby is granted a deviation from the water storage requirements of 807 KAR 5:066, Section 5(4), for so long as its agreement with the City of Murray remains in effect, but no later than July 1, 1994.

Done at Frankfort, Kentucky, this 7th day of January, 1992.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director